

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F6/DFS/MS/2021/ 438

Dated: 6 /07/2021

FIRE SAFETY CERTIFICATE

Certified that the building Swiss Cottage school located at Village Salahpur, New Delhi – 110061, comprised of Ground + two Upper Floor was issued Fire Safety Certificate vide this department letter No. F6/DFS/MS/School/2018/SZ/1337 Dated 07/06/2018. The premises was re inspected by the officer concerned of this department on 14/06/2021 in the presence of Sh. Mukesh Bhardwaj (HM) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance DOE Circular no. 3298-3398 dated 1-3-2011 and that the building is fit for occupancy class B “Educational building” with effect from 6/7/21 for a period of three years. Subject to compliance of the conditions given below.

Issued on 6/7/21 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. The Principal Swiss Cottage school located at Village Salahpur, New Delhi – 110061
2. Directorate of Education Old Secretariat Delhi – 110054.
3. The Vice Chairman, DDA, INA Vikas Sadan, New Delhi-110023.
4. The Commissioner, North Delhi Municipal Corporation, Civic Centre, Minto Road, New Delhi -110002.

Following fire safety directives must be adhered to:-

- 1 **The block comprising of Ground + one upper floor seen in the school premise, shall not be used for school activities without getting FSC from this department.**
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 8 Basement shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.